

Bedrijf
Locatie:
Naam:
Gegevens

Dunea
Monster
Drinkwater
2e kwartaal 2022

J.W. Lucasweg 2
2031 BE Haarlem

Postbus 734
2003 RS Haarlem
t 023-517 59 00
e info@hetwaterlaboratorium.nl

| Parameter | Eenheid | minimum | gemiddelde | maximum | norm DWB minimum | norm DWB maximum |
|----------------------------|------------|----------|------------|----------|------------------|------------------|
| Aluminium | µg/l | 5.5 | 5.5 | 5.5 | | 200 |
| Arseen | µg/l | 2.2 | 2.5 | 2.7 | | 10 |
| Boor | mg/l | 0,040 | 0,040 | 0.040 | | 0.5 |
| Calcium | mg/l | 43.64 | 44.31 | 44.66 | | |
| Chloride | mg/l | 42 | 43 | 44 | | 150** |
| Koolstofdioxide | mg/l | 1,0 | 1.3 | 1.7 | | |
| Carbonaat | mg/l | < 5 | 5 | 9 | | |
| Koper | µg/l | < 0.5 | < 0.5 | < 0.5 | | |
| Geleidingsvermogen | mS/m | 46.5 | 47,0 | 47.6 | | <125 |
| Fluoride | mg/l | 0.18 | 0.19 | 0.20 | | 1.0 |
| IJzer | mg/l | < 0.005 | < 0.005 | < 0.005 | | 0.2 |
| Troebelingsgraad | FTU | < 0.03 | < 0.03 | < 0.03 | | 1 |
| Geur | | afwezig | afwezig | afwezig | | **** |
| Waterstofcarbonaat | mg/l | 169 | 176 | 182 | >60 | |
| Kwik | µg/l | < 0.01 | < 0.01 | < 0.01 | | 1.0 |
| Totale hardheid | mmol/l | 1.43 | 1.45 | 1.46 | >1 | |
| Totale hardheid | °D | #WAARDE! | #WAARDE! | #WAARDE! | >5.6 | |
| Kleurintensiteit | mg/l Pt | 5 | 6 | 6 | | 20 |
| Magnesium | mg/l | 8.25 | 8.34 | 8.41 | | |
| Mangaan | mg/l | < 0.005 | < 0.005 | < 0.005 | | 0.05 |
| Natrium | mg/l | 44.2 | 44.2 | 44.2 | | 150 |
| Ammonium | mg/l NH4 | < 0.02 | < 0.02 | < 0.02 | | 0.2 |
| Nitriet (no2/l) | mg/l NO2 | < 0.007 | < 0.007 | < 0.007 | | 0.1 |
| Nitraat (no3/l) | mg/l NO3 | 3.15 | 4.37 | 5.26 | | 50 |
| Zuurstof | mg/l | 10,0 | 10,0 | 10.0 | >2 | |
| Lood | µg/l | < 0.2 | < 0.2 | < 0.2 | | 10 |
| Zuurgraad berekend | pH | 8.28 | 8.42 | 8.52 | 7.0 | 9.5 |
| Orthofosfaat (po4/l) | mg/l PO4 | 0.12 | 0.12 | 0.12 | | |
| Seleen | µg/l | < 0.5 | < 0.5 | < 0.5 | | 10 |
| Verzadigingsindex berekend | pH | 0.52 | 0.63 | 0.72 | > -0.2 | |
| Smaak | | afwezig | afwezig | afwezig | | **** |
| Sulfaat | mg/l | 41.2 | 42.1 | 43.0 | | 150 |
| Temperatuur | °C | 9.6 | 10.8 | 12.4 | | 25 |
| Organisch koolstof totaal | mg/l | 2.19 | 2.32 | 2.50 | | **** |
| Aeromonas | kve/100 ml | 0 | 1 | 3 | | 1000 |
| Coli | kve/100 ml | 0 | 0 | 0 | | 0 |
| Clostridium perfringens | kve/100 ml | 0 | 0 | 0 | | 0 |
| Enterococcen | kve/100 ml | 0 | 0 | 0 | | 0 |
| Koloniegetal-gp-22 | kve/ml | 0 | 1 | 1 | | 100*** |
| Legionella | kve/l | <100 | <100 | <100 | | <100 |

** norm jaargemiddelde *** norm geometrisch jaargemiddeld **** geen abnormale verandering